

ADDENDUM TO RFP DOCUMENTS

REQUEST FOR PROPOSAL

REPLACEMENT OF DUCTLESS MINI-SPLIT HEAT PUMP

CENTERVILLE BRANCH

206 GUNN ROAD

CENTERVILLE GA 31028

ADDENDUM No. 1

DATE: 2/7/2019

To All Potential Bidders:

This addendum is issued to modify the previously issued RFP and is hereby made a part of the bid documents. Please attach this addendum to the documents in your possession.

Modifications / Clarifications

Section 2.

Scope of Work, paragraph a.: The sentence has been changed to read that the current conditioning unit is 12,000 BTU, not 18,000 BTU.

Minimum Requirements, paragraph a.: The BTU value has been changed to 12,000 BTU.

Other Requirements, paragraph a: Paragraph a has been removed in its entirety. There is no requirement for the replacement unit to be connected to the HVAC controls.